



## RoHS-3 CERTIFICATE OF COMPLIANCE RoHS-3 DIRECTIVE 2015/863/EU

This statement certifies the products manufactured by Thermalogic Corporation are RoHS 3 compliant and do not to the best of its knowledge contain substances listed in the table below in excess of the Maximum Concentration Value ( MCV) as outlined in the directive RoHS 2015/863/EU in force June 4, 2015.

SUBSTANCE	MCV
Lead (PB)	0.1% by weight (1000 ppm)
Mercury (Hg)	0.01% by weight (100 ppm)
Cadmium (Cd)	0.01% by weight (100 ppm)
Hexavalent Chromium: (Cr VI)	0.1% by weight (1000 ppm)
Polybrominated Biphenyls (PBB)	0.1% by weight (1000 ppm)
Polybrominated Diphenyl Ethers (PBDE)	0.1% by weight (1000 ppm)
Bis( 2-Ethylhexyl ) phthalate (DEHP)	0.1% by weight (1000 ppm)
Benzyl butyl phthalate (BBP)	0.1% by weight (1000 ppm)
Dibutyl phthalate (DBP)	0.1% by weight (1000 ppm)
Diisobutyl phthalate (DIBP)	0.1% by weight (1000 ppm)

All temperature sensors manufactured by Thermalogic Corporation are RoHS-3 compliant.

All components used in the manufacturing of electronic controls by Thermalogic Corporation are RoHS-3 compliant.

RoHS-3 compliancy of finished electronic controls by Thermalogic Corporation is executed on a per job basis and Thermalogic Corporation can manufacture the finished product to RoHS-3 compliancy upon customer request. Please contact us regarding RoHS compliancy for your specific product and updated price quote.

We at Thermalogic want to reiterate that we remain a concerned and strategic partner for all your process control needs. Please feel free to contact us if there any questions.

*Eric Lundberg*

Eric Lundberg  
Vice President

[sales@thermalogic.com](mailto:sales@thermalogic.com)

**800-343-4492**

[www.thermalogic.com](http://www.thermalogic.com)

**Thermalogic Corporation • 22 Kane Industrial Drive • Hudson, MA 01749**

Thermalogic is a registered trademark and TempGuard, AccuSense, AccuTherm, Master Series, HumiSense, DigiTherm, and SureSignal are trademarks of Thermalogic Corporation.